



**REEDY CREEK
IMPROVEMENT DISTRICT**

P.O. BOX 10170, LAKE BUENA VISTA, FLORIDA 32830-0170 TELEPHONE (407) 828-2034 FAX (407) 828-2416

BUILDING AND SAFETY

TEMPORARY GAS HEATERS

The use of temporary gas heaters is allowed for the heating of spaces under the following conditions:

1. All gas heaters shall be of the radiant heat type (no open flame).
2. All gas heaters shall be equipped with a tip over safety shutdown feature.
3. All gas heaters shall be listed and approved by a Nationally Recognized Testing Laboratory and installed per the listings (a copy of the listings shall be on site for inspector to review).
4. All liquid propane tanks shall be installed outside the structure and secured to prevent tip over and/or physical damage.
5. All gas lines from the tank to the heater shall not be installed in walkways or areas where gas line is subjected to damage and shall be listed for LP gas use.
6. All gas heaters shall be installed with the required distance from flammable or combustible materials.
7. All gas heater installations shall require a permit and inspections by this Department and be installed by a licensed LP gas installer.
8. This department, prior to installation, must approve gas heaters and liquid propane cylinders that are one unit.

Please be aware that this list may not be complete due to the wide variety of gas heater styles, manufacturer requirements, and type of installation.