

THEME PARK FOOD AND MERCHANDISE CARTS, KIOSKS AND PORTABLE STRUCTURES REQUIREMENTS

DEFINITIONS

Cart. A mobile unit that is easily moveable by no more than two persons and may require some disassembly prior to transport or storage.

Kiosk. A kiosk is defined as a small structure, no larger than 200 square feet, which may be portable through more extensive disassembly, but is primarily intended as permanent. It may be constructed on- or off-site, then anchored and connected to utilities as permanent.

Mobile Food Dispensing Vehicle. A vehicle mounted public food service establishment, self-propelled or otherwise moveable from place to place. Such vehicles must be self-sufficient for utilities. Each mobile food dispensing vehicle is required to have a State approved commissary that it reports to at least once a week.

Portable Structure. A portable structure is defined as movable by more than two persons or with equipment and may require some disassembly to be performed prior to transport or storage.

REQUIREMENTS

Note: All vendors shall adhere to the following requirements for installation and use.

1. All carts, kiosks and/or portable structures shall be required to be constructed and anchored to meet the design for wind loadings as required by the *EPCOT Building Code* Section 904.

Exception: The Applicant shall provide a letter stating that the cart or portable structure will be removed upon warning of a hurricane.

- (a) All Disney owned carts or portable structures will require a letter from the Vice President of the area where a cart or portable structure is installed, stating the location where the cart or portable structure will be stored for the duration of a hurricane.
 - (b) All other vendor owned carts or portable structures will require a letter from the owner stating that the cart or portable structure will be removed from Reedy Creek Improvement District's (the District) jurisdiction upon warning of a hurricane and the means of removal.
2. A backflow preventer shall be installed for all potable water hose connections or connections that are hard piped.
 3. If a waste holding tank is utilized, an alarm and automatic water shut-off valve shall be installed if the potable water is connected to a hose bib (with a hose approved for potable water use) or a hard pipe connection is used (must incorporate a union for disconnecting purposes). If a potable water tank is used along with a waste holding tank, the water tank shall be 25% smaller than the waste holding tank.

4. If the water pressure exceeds 80 psi, a pressure reducer shall be installed.
5. All electrical and gas devices or equipment shall bear the label of a Nationally Recognized Testing Laboratory.
6. A disconnecting means for the electrical system shall be provided, except on carts, kiosks or portable structures that utilize a plug and cord for main power.
7. All cooking that produces smoke and/or grease laden vapors shall be installed under an approved exhaust hood incorporating an approved fire suppression system as required by Reedy Creek Improvement District Emergency Services.
8. Permits shall be required for all utility connections installed to service a cart, kiosk or portable structure and shall be applied for by Florida licensed contractors (electrical, plumbing, etc.).
9. The Building and Safety Department must issue a Building permit for any cart, kiosk or portable structure. Once the cart, kiosk or portable structure is in place, the owner shall request an inspection from Building and Safety. Utilities cannot be energized until all inspections are approved.
10. All water piping and water holding tanks shall be chlorinated and have bacteriological tests performed and approved before use of a cart, kiosk or portable structure is permitted. (Note: For permits requiring a bacteriological test, a minimum of five (5) days' notice is required for scheduling the test. Contact Bill Schaeffer at (407) 824-4596 to schedule testing.)
11. A cart, kiosk or portable structure shall only be used at an approved location. If a cart, kiosk or portable structure is to be moved to another location, approval from the Building and Safety Department and the Planning and Engineering Department is required prior to the move.
12. Kiosks, permanent or temporary, shall be separated not less than 15 feet from other permanent or temporary structures.